



16

### 420A – Whole Room Cooling CRAHs on North, Move Panel E/W Row Arrangement

- A. Infrastructure Row for
  - 1. Modular PDUs ala APC PDPM144F – 300mm
  - 2. UPS
  - 3. Network Aggregation/Services
  - 4. Other options/uses TBD
- B. Electrical Panel
- C. APC Uniflair Chiller (Example)
  - 1. 130KW Model - 28" clearance in front
  - 2. ~ 34" x 101.6"
  - 2. must have underfloor clearance for airflow
- F. APC AR3100 600mm x 1070mm 42U
- G. APC AR8561 Cable Troughs

-  Underfloor Clearance
-  Work Area Clearance

20" deep concrete  
shelf under floor

0 ft. 3 ft. 5 ft. 10 ft.

